

26 08 06 - PANELBOARD CHECK SHEET

SBC Project No:		Page		of	
Institution or Campus:		Date:			
Building:		Tests run by:			
Installer:					

System/Unit Identifier:

Location:

ITEM	PANEL	PANEL	PANEL	PANEL
Room sprinkler				
Pipes above panel				
Room air conditioned				
NEC code space				
Conduits secured				
Fire caulking				
Ground buss				
MCB/MLO				
kAIC rating				
Panel Manufacturer				
Panel model number				
Panel circuits ID				
Wire colors				
One wire per breaker				
Wires neatly terminated				
Spare breakers off				
Panel clean				
Measurements				
A amps				
B amps				
C amps				
N amps				
Ground amps				
A-N volts				
B-N volts				
C-N volts				
A-B volts				
A-C volts				
B-C volts				
N-G volts				